



<b>DOCUMENT NO.:</b> DND-IH-PRO-00049	<b>REV. NO.</b> 0	<b>EFFECTIVE DATE:</b> <u>4/1/26</u>
<b>TITLE:</b>  Confined Space Program	<b><u>5</u> YR PERIODIC REVIEW DATE:</b> <u>3/19/31</u>	
	<b>APPROVED BY:</b> <b>DATE:</b>	<b>Brandon Arthur</b> <b>3/19/26</b> <b>(Signature on File)</b>

<b>USE CATEGORY:</b>	<b>INFORMATION USE</b>	<b>Page 1 of 35</b>
<b>SME:</b> Ryan Campbell	<b>Writer:</b> Sharon Hoskins	

**Level 2 Administrative Procedure**

Revision	Record of Issue/Revision	Affected Pages
0	Revision/Periodic Review: Initial Release under Southern Ohio Cleanup Company LLC (SOCCo) from FBP-IH-PRO-00049, Rev. 9. Converted procedure to new SOCCo branding/template/formatting. Updated forms F01 and F03, to remove redundant information, provide clarifications, and incorporate process improvements. Additional minor administrative changes as needed.	All

Previous Record of Issue/Revision information is available from the history files.

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 2 of 35</b>

## CONTENTS

1.0	PURPOSE.....	4
2.0	SCOPE AND APPLICABILITY .....	4
3.0	GENERAL INFORMATION.....	4
4.0	USE REFERENCES .....	4
5.0	RESPONSIBILITIES .....	5
5.1	Confined Space Program Manager (CSPM) .....	5
5.2	Occupational Safety and Health (OS&H) Professional .....	5
5.3	Competent Person .....	5
5.4	Confined Space Entry Supervisor .....	5
5.5	Supervisor/Facility Manager.....	6
5.6	Authorized Attendant.....	6
5.7	Authorized Entrant.....	6
5.8	Fire Services/Emergency Rescue Personnel .....	6
5.9	SOCCo Training Professional.....	6
6.0	ACTIONS.....	7
6.1	Preferred Methods of Reducing Risks to Personnel.....	7
6.2	Training.....	8
6.3	Fire Services/Emergency Rescue Personnel .....	9
6.4	Baseline Evaluation and Classification.....	10
6.5	Confined Space Entry Classifications.....	11
6.6	Permit Process Initiation for Upcoming Work.....	11
6.7	Confined Space Danger Signs.....	11
6.8	Atmospheric Testing and Surveillance .....	12
6.9	Safe Work Practices and Controls.....	13
6.10	Industrial Hygiene (IH) Aspects .....	15
6.11	Lighting.....	15
6.12	Electrical Equipment.....	16
6.13	Non-Powered Hand Tools.....	16
6.14	Compressed Gas/Flame-Producing Equipment .....	16
6.15	Ventilation Equipment .....	17
6.16	Safety Retrieval Equipment .....	17
6.17	Emergency Rescue Consideration.....	18

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 3 of 35</b>

6.18	Completing the Confined Space Entry Permit .....	19
6.19	Pre-entry Briefing and Equipment Check .....	20
6.20	Performing Permitted Confined Space Entries .....	21
6.21	Post-Performance Work Activities .....	24
6.22	Emergency Response Actions.....	24
6.23	Program Evaluations .....	25
7.0	RECORDS.....	25
7.1	Records Generated .....	25
7.2	Requirements .....	25
8.0	DEFINITIONS/ACRONYMS.....	25
8.1	Definitions.....	25
8.2	Acronyms .....	29
Appendix A	SOURCE REFERENCES AND REGULATORY REQUIREMENTS .....	30
Appendix B	CONFINED SPACE DANGER SIGNS.....	31
Attachment A	CONFINED SPACE ENTRY PERMIT .....	32
Attachment B	CONFINED SPACE IDENTIFICATION AND EVALUATION .....	35

<b>TITLE:</b>  <p style="text-align: center;"><b>Confined Space Program</b></p>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 4 of 35</b>

## 1.0 PURPOSE

- 1.1 This procedure has been developed to implement applicable requirements for confined space work and entry.
- 1.2 This procedure provides guidance on performing emergency rescues and rendering emergency aid to confined space workers.

## 2.0 SCOPE AND APPLICABILITY

- 2.1 This Level 2 procedure applies to confined space entries conducted by Southern Ohio Cleanup Company LLC (SOCCo) and contracted labor resources performing work at the Department of Energy Portsmouth Gaseous Diffusion Plant (PORTS).
- 2.2 This procedure provides instructions for the proper preparation, issuance, duration, and implementation of permits associated with confined space entry and work and defines the performance criteria and requirements for personnel entering confined spaces.
- 2.3 This procedure also provides guidance on performing emergency rescues and rendering emergency aid to confined space workers.
- 2.4 This procedure applies to individuals who enter confined spaces, supervise work within confined spaces, conduct atmospheric testing of confined spaces, and/or perform emergency rescue within confined spaces.

## 3.0 GENERAL INFORMATION

- 3.1 Under normal circumstances, the physical and operational characteristics of fan houses, spaces above suspended ceilings, attics, crawl spaces, cooling towers, vertical pipe chases, and basements do not warrant the restrictions generally imposed for confined space entry and work.
- 3.2 DND-IH-PRO-00049-F01, *Confined Space Entry Permit*, is commonly referred to throughout this procedure as “Confined Space Entry Permit” or CSEP.

## 4.0 USE REFERENCES

- A. American Conference of Governmental Industrial Hygienists (ACGIH), Threshold Limit Values TLVs)
- B. DND-BS-PRO-00062, *Records Management Process*
- C. DND-IH-PRO-00024, *Industrial Hygiene Sampling*
- D. DND-IH-PRO-00024, *Industrial Hygiene Sampling*
- E. DND-NSE-PRO-00002, *Pre-Job Briefing and Post-Job Review*
- F. DND-OS-PRO-00068, *Instructions for Lockout/Tagout*

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 5 of 35</b>

## 5.0 RESPONSIBILITIES

### 5.1 Confined Space Program Manager (CSPM)

- 5.1.1 Coordinates program oversight, space evaluations, and procedure updates.
- 5.1.2 Maintains authority in confined space matters.
- 5.1.3 Resolves any disagreements with the final identification, classification, and reclassification of confined spaces.
- 5.1.4 Maintains inventory of permanent confined space locations.
- 5.1.5 Identifies competent persons in accordance with DND-OS-PRD-00002, *Competent Person Program*.
- 5.1.6 Assists with classifications of confined spaces.

### 5.2 Occupational Safety and Health (OS&H) Professional

- 5.2.1 Conducts air monitoring as required.
- 5.2.2 Issues CSEP numbers to requestors after verifying through the confined space inventory that the confined space has been previously evaluated.

### 5.3 Competent Person

- 5.3.1 Evaluates spaces to determine if the space meets the definition of a confined space.
- 5.3.2 Classifies the space as permit-required or non-permit, based on the definitions in Subsection 8.1, *Definitions*.
- 5.3.3 Assesses hazards of the permit-required confined space (PRCS).
- 5.3.4 Recommends appropriate engineering and administrative controls to minimize hazards of the PRCS.
- 5.3.5 Authorizes or prohibits entry into the PRCS, based on the atmospheric and physical hazards of the space and type of work to be performed.

### 5.4 Confined Space Entry Supervisor

- 5.4.1 Maintains overall responsibility for the PRCS entry operation.
- 5.4.2 Serves as an Authorized Attendant or Authorized Entrant as long as that individual is trained and equipped, as required, for each role he or she fulfills.
- 5.4.3 Passes duties from one properly trained individual to another during the course of the entry operation, as necessary.

<b>TITLE:</b>	<b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
		<b>REV. NO. 0</b>
		<b>Page 6 of 35</b>

5.4.4 Ensures that subordinates understand the hazards associated with the CSEP spaces within his/her work areas.

5.4.5 Ensures appropriate personal protective equipment (PPE) is used according to work documents (e.g., Job Hazard Analysis [JHA]).

**5.5 Supervisor/Facility Manager**

5.5.1 Initiates CSEP.

5.5.2 Ensures that the CSEP areas within his/her work areas are properly identified, posted, and maintained.

5.5.3 Ensures designated personnel are properly trained.

**5.6 Authorized Attendant**

5.6.1 Ensures the safety of the Authorized Entrant during confined space entries.

5.6.2 Reviews the hazards present in a confined space with the Confined Space Entry Supervisor prior to allowing entry by the Authorized Entrant.

**5.7 Authorized Entrant**

5.7.1 Complies with the direction given by the Authorized Attendant during confined space entries.

5.7.2 Reviews the hazards present in the confined space with the Confined Space Entry Supervisor prior to entering the confined space.

5.7.3 Performs work in accordance with applicable permits or procedures.

**5.8 Fire Services/Emergency Rescue Personnel**

5.8.1 Provides emergency rescue services, as needed.

5.8.2 Recommend appropriate retrieval devices for entry into the PRCS.

5.8.3 Utilizes basic first aid and cardiopulmonary resuscitation (CPR) knowledge and skills and renders necessary emergency services to rescue confined space workers as necessary.

**5.9 SOCCo Training Professional**

5.9.1 Assists subject matter expert in development of confined space training modules.

5.9.2 Provides training for designated personnel.

5.9.3 Maintains confined space training records.

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 7 of 35</b>

## **6.0 ACTIONS**

### **6.1 Preferred Methods of Reducing Risks to Personnel**

#### **Supervisor**

- 6.1.1** Review the proposed work to identify the confined space in which the work will be conducted.
- 6.1.2** Contact OS&HP, as necessary, to begin the CSEP issuance process.

#### **Confined Space Entry Supervisor**

- 6.1.3** Convey information concerning any chemical hazards associated with the confined space entry to employees potentially exposed to that chemical hazard using the following as needed:
  - JHAs
  - Work Packages
  - Pre-job briefs
  - Lessons Learned
  - Safety Data Sheet (SDS)
- 6.1.4** Complete standard, and supervisor confined space training prior to confined space work.
- 6.1.5** Coordinate the entry operations.
- 6.1.6** Request support from the involved Supervisor(s) and OS&H, as needed, when entry operations are conducted simultaneously by employees performing more than one activity (this ensures that activities of different trades do not endanger each other).
- 6.1.7** Ensure worker's confined space training is current.
- 6.1.8** Ensure that removable barricades are used and confined space warning signs are posted to prevent inadvertent entry when access is provided for work in the CSEP spaces that are not previously posted.
- 6.1.9** Ensure that engineering controls (supplemented by administrative controls and PPE, as required) have been implemented (whenever feasible) by incorporating accepted engineering control measures, such as general or local ventilation, or by redesigning job tasks so that personnel entry into confined spaces is unnecessary.

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 8 of 35</b>

## **6.2 Training**

### **CSPM**

**6.2.1** Ensure that individuals conducting confined space training for SOCCo are knowledgeable in the following aspects of confined space entry:

- Hazard recognition
- Use of PPE
- Safety and Integrated Safety Management
- Lessons Learned (related to Confined Space Program issues)
- Communication methods
- Safety retrieval equipment
- Requirements specified by applicable regulations, standards, and procedures

**6.2.2** Verify that standard confined space and emergency responder training includes the following:

- An explanation of the general hazards associated with confined spaces and a discussion of why people could die in confined spaces
- A discussion of the particular confined space hazards associated with a specific site, location, or work activity
- The reason for, correct use of, and limitations of PPE and other safety equipment required for entry into confined spaces
- An explanation of the permit system and other procedural requirements for conducting a confined space entry
- A description of confined space job tasks and responsibilities, based on functional role (entrant, attendant, entry supervisor, etc.)
- A discussion of how to recognize symptoms of oxygen deficiency and overexposure to air contaminants in oneself and in others
- A discussion of methods for alerting attendants
- A discussion of how to respond to emergencies

<b>TITLE:</b>	<b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
		<b>REV. NO. 0</b>
		<b>Page 9 of 35</b>

**6.2.3** Verify that general confined space training includes the following:

- Methods for summoning rescue or emergency services
- The proper use of communication equipment used to establish and maintain contact with confined space entrants and emergency/rescue personnel
- Recognition of signs/symptoms of potential overexposure

**Confined Space Entry Supervisor**

**6.2.4** Complete general and supervisor confined space training prior to confined space work.

**6.2.5** Ensure personnel assigned functional responsibilities for confined space activities, such as attendants, entrants, and supervisors, are provided training in the following circumstances:

- Before performance of confined space duties
- When there is a change in assigned duties requiring confined space entry and work
- When there is a change in permit space operations that presents a hazard about which an employee has not previously been trained
- When there is reason to believe either that there are deviations from the permit space entry procedures or that there are inadequacies in the employee's knowledge or use of the confined space procedure

**NOTE**

All entrants must have confined space training for permit & non permit entries.

**6.3 Fire Services/Emergency Rescue Personnel**

**Fire Services Manager**

**6.3.1** Verify that emergency response personnel assigned to perform confined space rescue have completed Confined Space Emergency Rescue Training that includes the following:

- The use of PPE, such as self-contained breathing apparatus (SCBAs), protective clothing, etc., for performing rescues
- The use of confined space emergency rescue equipment, such as tripods, mechanical retrieval devices, high-angle rescue equipment, radios, etc.
- First aid and CPR techniques

<b>TITLE:</b>	<b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
		<b>REV. NO. 0</b>
		<b>Page 10 of 35</b>

- Familiarity with the different types of confined spaces at the site
- Participation in annual simulated rescue operations from representative confined spaces at the site

**6.3.2** Develop and modify confined space entry rescue training materials.

**6.3.3** Ensure that confined space rescue and related equipment used by the Fire Department and Emergency Squad personnel is properly maintained, inspected, and stored in a manner that ensures readiness for emergency use.

**6.3.4** Ensure that atmospheric testing equipment in possession is approved for use in hazardous atmospheres and is properly maintained and calibrated.

#### **SOCCo Training Professional**

**6.3.5** Maintain approved lesson plans and attendance sheets for confined space rescue training.

**6.3.6** Ensure that a register of trained persons for confined space entry rescue is maintained in an auditable and retrievable format.

#### **Fire Services Personnel**

**6.3.7** Participate in annual confined space rescue simulations designed to demonstrate the use of actual rescue equipment.

**6.3.8** Follow approved practices when conducting an emergency response.

### **6.4 Baseline Evaluation and Classification**

#### **Competent Person/CSPM**

**6.4.1** Schedule and conduct an initial baseline inventory/evaluation of confined spaces when requested by the confined space owner.

**6.4.2** Evaluate the space and classify it as either a permit-required or non-permit confined space based on the definitions in Subsection 8.1.

**6.4.3** Complete DND-IH-PRO-00049-F03, *Confined Space Identification and Evaluation*, and give to CSPM.

#### **CSPM**

**6.4.4** Coordinate with the project lead and perform a survey of the premise and/or operation to identify and classify confined spaces.

**6.4.5** Develop and maintain an inventory of confined spaces.

**6.4.6** Provide technical guidance and regulatory interpretations to ensure consistent implementation of the Confined Space Program.

TITLE:  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 11 of 35</b>

## 6.5 Confined Space Entry Classifications

### CSPM/Competent Person

Use DND-IH-PRO-00049-F03 to identify and classify or re-classify spaces and determine the requirements for safe accomplishment of an entry operation. Return all forms to CSPM.

## 6.6 Permit Process Initiation for Upcoming Work

### Supervisor /Facility Manager

6.6.1 Initiate the CSEP.

**NOTE**

Any member of OS&H may assist in getting a CSEP permit number.

6.6.2 Contact OS&H for a CSEP permit number.

6.6.3 Record the confined space permit number on CSEP.

### CSPM

6.6.4 Maintain a log of the unique identifier numbers for CSEPs.

6.6.5 Start a new numbering sequence annually (each calendar year).

6.6.6 Track the numbers to ensure that completed CSEPs are returned.

### OS&H Professional

6.6.7 Confirm evaluation of confined space has been completed.

6.6.8 Issue CSEP #.

6.6.9 Contact competent persons for evaluations.

### Facility Manager/Confined Space Owner

6.6.10 Ensure that uncontrolled access points to all PRCs that may be inadvertently entered are posted with signs appropriate for the confined space, according to Appendix B, *Confined Space Danger Signs*.

6.6.11 Ensure that confined space signs are maintained and in a legible condition.

## 6.7 Confined Space Danger Signs

### Facility Manager/Confined Space Owner

6.7.1 Ensure that uncontrolled access points to all PRCs that may be inadvertently entered are posted with signs appropriate for the confined space according to Appendix B.

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 12 of 35</b>

**6.7.2** Ensure that confined space signs are maintained and in a legible condition.

## **6.8 Atmospheric Testing and Surveillance**

### **OS&H Supervisor**

**6.8.1** Ensure personnel who perform atmospheric testing for confined space are trained and understand the following:

- A. Basic knowledge of the work being performed
- B. Anticipated hazardous contaminants
- C. Any process that could significantly alter the original conditions under which the confined space entry was classified

### **OS&H Professional**

**6.8.2** Determine whether continuous monitoring is required for confined space entries with help from an Industrial Hygienist.

**6.8.3** Perform atmosphere testing in any of the following circumstances:

- A. When atmospheric hazards constitute the reason for an entry to be classified as a permit required entry
- B. At a time interval specified by CSEP, not to exceed 8 hours between initial atmospheric testing, and retesting regardless of the classification prior to entry

**6.8.4** **IF** a confined space is vacated and unsecured for any period of time and it is suspected by any employee or indicated that a change in condition of the space has occurred, **THEN** retest the CSEP space to ensure that conditions have not changed since the original entry.

**6.8.5** **WHEN** portable mechanical ventilation is used, **THEN** conduct initial atmospheric testing first with the ventilation off and then subsequently with the ventilation on.

#### **NOTE**

Testing stratified atmospheres: When monitoring for entries involving a descent into atmospheres that may be stratified, the atmospheric envelope should be tested approximately 4 feet (1.22m) in the direction of travel and to each side. If a sampling probe is used, the entrant's rate of progress should be slowed to accommodate the sampling speed and detector response.

**6.8.6** Perform atmospheric testing of the CSEP space in the following sequence:

- A. Oxygen
- B. Flammability

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 13 of 35</b>

C. Toxic substances

**6.8.7** Note the atmospheric results based on type:

A. Initial/interval on CSEP

B. Continuous on DND-IH-PRO-00024-F04, *Industrial Hygiene Direct Reading Survey*, or DND-IH-PRO-00024-F05, *Industrial Hygiene Direct Reading Survey Continuation Form*

**6.8.8** Document type and frequency of testing/retesting on CSEP to ensure that conditions within the space remain acceptable during entry.

**NOTE**

If the survey is done, a copy needs provided for CSEP.

**Authorized Entrant (or that employee's authorized representative)**

**6.8.9** Observe and report atmospheric testing, if desired.

**6.9 Safe Work Practices and Controls**

**Confined Space Entry Supervisor**

**6.9.1** Request a pre-entry risk evaluation from the appropriate discipline(s) (OS&H, Radiation Protection, Fire Protection, etc.), as needed, based on the anticipated hazards and the work to be performed.

**6.9.2** Perform the following, as appropriate, to verify that necessary items have been developed and implemented for safe permit space entry operations:

A. Ensure that required permits (CSEPs, radiation, welding/hot work, Lockout/Tagout [LOTO], etc.) associated with the PRCS have been signed, as appropriate, and issued.

B. Ensure that warning systems and barricades meet the following requirements:

- Installed at the entrance(s) to confined spaces that have the potential for objects or persons to fall into the space. Such protection will be installed such that it does not affect the ventilation of or egress from the confined space.
- Barricades established, as necessary, to protect entrants from potential external hazards caused by pedestrians, vehicles, etc.

C. Ensure that safe entry and exit for entrants, such as ladders and/or other equipment, will be installed and/or provided, as appropriate.

<b>TITLE:</b>  <p style="text-align: center;"><b>Confined Space Program</b></p>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 14 of 35</b>

- D. Ensure that monitoring is in place to verify that conditions in the CSEP space have been established and are acceptable throughout the duration of the authorized entry.
- E. Ensure the following for isolation:
  - 1) Ensure appropriate isolation has been applied to lines/systems servicing confined spaces where toxic, hazardous, or radioactive materials pose a high risk to personnel due to the potential for engulfment, high temperature, high pressure, etc.
  - 2) Ensure specific methods of isolation are determined, based on consultation of the Entry Supervisor with OS&H, craft, and supervision, as appropriate. Methods may include:
    - Blinding/blanking
    - Double block and bleed, and disconnection. **WHEN** using double block and bleed measures, **THEN** assurance must be made that the bleed valve is not inadvertently plugged
  - 3) Consider the compatibility of the isolation material with the contents of the system being isolated.

**Authorized Entrant**

- 6.9.3 Complete initial confined space training prior to confined space work.
- 6.9.4 Verify that the systems within the PRCS are LOTO according to DND-OS-PRO-00068, *Instructions for Lockout/Tagout*.

**Fire Protection Professional**

- 6.9.5 Approve mechanical ventilation to be used to reduce/purge flammable substances prior to use in flammable environments (e.g., Class I, Division 2 locations).

**Confined Space Entry Supervisor**

- 6.9.6 Verify that the systems within the PRCS have been adequately addressed by performing the following:
  - A. Ensure confined spaces have been emptied, flushed, or otherwise purged of flammable, hazardous, toxic, radioactive, or incapacitating substances to the extent feasible prior to entry.
  - B. Ensure the confined space is being mechanically ventilated to reduce and maintain toxic or hazardous contaminants to safe levels, as necessary, by forcing air into the space and not pulling air from it.
  - C. **IF** safe levels cannot be achieved, **THEN** implement additional ventilation or other engineering controls to reduce contaminants to the lowest level feasible.

TITLE:	<b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
		<b>REV. NO. 0</b>
		<b>Page 15 of 35</b>

**WARNING**

**Do NOT use pure oxygen to ventilate a confined space.**

**D. IF** there is a potential for atmospheric change to unacceptable levels, **THEN** maintain ventilation during confined space occupancy.

**NOTE**

Continuous monitoring may be performed by the entrant/attendant using a portable monitoring device.

**E.** Ensure continuous monitoring of systems (such as sewer systems) or other large spaces when isolation is infeasible.

## **6.10 Industrial Hygiene (IH) Aspects**

### **Competent Person**

- 6.10.1** Ensure that an initial (baseline) evaluation is performed based on the risks associated with each identified confined space and when requested by the confined space owner, such as Facility Manager, Project Lead, Subcontractor, or Entry Supervisor.
- 6.10.2** Evaluate pre-job safety and health hazards and the risks associated with each confined space entry upon request of the Confined Space Entry Supervisor.
- 6.10.3** Provide technical guidance and regulatory interpretations to ensure consistent implementation of the Confined Space Program.
- 6.10.4** Refer any confined space conflicts between OS&H and other organizations to the CSPM for resolution.

## **6.11 Lighting**

### **Confined Space Entry Supervisor**

- 6.11.1** Verify that lighting provided for use in confined spaces containing, or potentially containing, flammable vapors or explosive dusts is approved as explosion-proof lighting. This requirement also applies to low-voltage lighting, such as droplights and flashlights.
- 6.11.2** Verify that lighting powered by 110Volt (V), cord-connected systems is supplied with a ground-fault circuit interrupter (GFCI).

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 16 of 35</b>

## **6.12 Electrical Equipment**

### **Confined Space Entry Supervisor**

Verify that power tools used in confined spaces meet the following criteria:

- Are pneumatic or electric, when feasible
- Electric hand tools are explosive-proof if used in potentially flammable/explosive atmospheres
- Protected by a GFCI, where appropriate

## **6.13 Non-Powered Hand Tools**

### **Confined Space Entry Supervisor**

Ensure that non-powered hand tools used in confined spaces containing or potentially containing flammable vapors or explosive dusts are spark-proof or spark-resistant.

## **6.14 Compressed Gas/Flame-Producing Equipment**

### **OS&H Professional**

**6.14.1** Ensure that welding and cutting operations conducted in PRCSS are adequately ventilated to prevent accumulation of toxic materials or the formation of a possible oxygen-deficient atmosphere.

### **Confined Space Entry Supervisor**

**6.14.2** Ensure that compressed gas cylinders are not taken into confined spaces, except for the following:

- SCBA
- Resuscitation equipment
- Other emergency response/life support-related items (e.g., bottled air)

**6.14.3** Ensure that welding equipment is not used in confined spaces containing, or potentially containing, flammable vapors, explosive dusts, or explosive materials.

### **Authorized Attendant**

**6.14.4** Ensure that authorized entrants do not carry non-authorized spark or flame-producing devices, including lighters or matches, into confined spaces.

### **Authorized Entrant**

**6.14.5** Remove all electrodes from the holders when arc welding is to be suspended for any substantial period of time (i.e., 1 hour or greater).

TITLE:	<b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
		<b>REV. NO. 0</b>
		<b>Page 17 of 35</b>

6.14.6 Locate the holders so that accidental contact cannot occur.

6.14.7 Disconnect the arc welding machine from the power source.

## 6.15 Ventilation Equipment

### OS&H Professional

6.15.1 Verify that the air supply for ventilation equipment is from a clean source and does not increase the hazards in a confined space.

#### **WARNING**

**Exposure to dangerous concentrations of carbon monoxide without PPE or other safety controls may result in serious injury or death.**

6.15.2 Verify that air intakes for ventilation equipment are positioned away from sources of carbon monoxide, such as idling vehicles or operating electrical generators/air compressors powered by diesel fuel or gasoline.

6.15.3 **IF** sufficient ventilation cannot be obtained without blocking the means of access to the confined space, **THEN** ensure that authorized entrants are using airline respirators.

## 6.16 Safety Retrieval Equipment

### Confined Space Entry Supervisor

6.16.1 **IF** the use of the retrieval system increases the overall risks of entry (due to structures, equipment, or entanglement with other lines in the confined space), **THEN** consult a competent person and/or the CSPM to waive the requirement that all authorized entrants wear a safety harness and/or retrieval system into the confined space.

### Authorized Attendant

#### **NOTE**

The safety harness will permit lifting or dragging of an unconscious or incapacitated entrant by retrieval line connections either at both shoulders, at both wrists or by a single-line connection between the shoulders at the back.

6.16.2 Verify that all authorized entrants performing confined space entries wear a retrieval system consisting of a safety harness and retrieval line, if applicable.

<b>TITLE:</b>	<b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
		<b>REV. NO. 0</b>
		<b>Page 18 of 35</b>

**6.16.3** Ensure that a mechanical hoisting device is provided to retrieve personnel from a vertical entry into any confined space greater than 5 feet deep, when applicable, and that the hoisting device meets the following requirements:

- Manually powered by the mechanical advantage of pulleys, ratchets, etc., not electrically or pneumatically powered
- The mechanical advantage provided by the hoisting device is at least 4 to 1
- Designed such that the descent speed of suspended loads is limited to prevent injury of entrants falling during entry or rescue

**6.16.4** Ensure that the other end of the retrieval line is attached to a mechanical device or fixed point outside the confined space that is capable of supporting the suspended load.

**6.16.5** Ensure that overhead structures provided and used for attaching the hoist, tripod system, or similar mechanism are of sufficient height to lift entrants clear of the confined space and swing them onto an adjacent walking/working surface.

## **6.17 Emergency Rescue Consideration**

### **Authorized Attendant**

**6.17.1** Consult Fire Protection to ensure that the following provisions are evaluated and documented on the permit for PRCS entries, when applicable:

- Type and availability of rescue equipment needed, including harnesses, lifelines, lifting devices, lighting, communication devices, and other special equipment
- An effective means to summon emergency personnel in a timely manner, and an effective method for entrants to inform the attendant of an emergency

**6.17.2** Prevent entries into a CSEP space if it is considered to be immediately dangerous to life or health (IDLH), unless authorized by the Incident Commander (IC).

**6.17.3** Consult with the Entry Supervisor, as necessary, to assist in determining the emergency response requirements for a CSEP required entry.

### **Fire Protection Services/Emergency Recue Professional**

**6.17.4** Utilize Fire Plan criterion in conjunction with this procedure for responding to confined space emergency events.

**6.17.5** Read posted warning signs prior to attempting rescue.

**6.17.6** Enter the confined space, if no expeditious alternative rescue method external to the confined space is available.

<b>TITLE:</b>	<b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
		<b>REV. NO. 0</b>
		<b>Page 19 of 35</b>

**6.17.7** Utilize either a mechanical hoist, tripod system, harness, tagline, or similar mechanism, and equipment, to rescue entrants from confined spaces and relocate them to an adjacent walking/working surface.

**6.17.8** Render necessary emergency services to rescued confined space workers utilizing basic first aid and CPR knowledge and skills, as necessary.

## **6.18 Completing the Confined Space Entry Permit**

### **Confined Space Entry Supervisor**

**6.18.1** Ensure the following is documented on the CSEP.

- A.** Hazards associated with the confined space entry
- B.** Methods of isolation/tagout (if necessary) and/or LOTO of the confined space
- C.** Methods used to remove or control particular hazards (e.g., purging, flushing, ventilating, and/or otherwise rendering a hazard inert [inerting])
- D.** Verification that rescue services are notified and available
- E.** Means of communication to be used by entrants and attendants to maintain contact and summon emergency/rescue personnel
- F.** PPE (e.g., respirators, clothing, retrieval lines)
- G.** Any other information necessary to ensure the safety and health of personnel who perform the confined space entry

**6.18.2** Sign the completed CSEP.

**6.18.3** Review CSEP with Entrants and Attendants.

#### **NOTE**

Each CSEP and assigned permit number is valid for the duration of the assigned task or 7 consecutive workdays, whichever is of shorter duration.

**6.18.4** **IF** a CSEP extension becomes necessary, **THEN** coordinate an extension with OS&H.

**6.18.5** Terminate (i.e., cancel) the CSEP when one or more of the following conditions are met:

- A.** Entry operations covered by the CSEP have been completed
- B.** Conditions or work activities are different than those specified on the CSEP.

<b>TITLE:</b>	<b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
		<b>REV. NO. 0</b>
		<b>Page 20 of 35</b>

C. A new hazard is introduced within the confined spaces.

**6.18.6** Document all problems encountered during entry operations on CSEP so that appropriate revisions to the permit space program can be made.

**6.18.7** Return all canceled CSEPSs to the CSPM for annual review.

**OS&H Professional**

**NOTE**

If the work scope remains the same, an extension can be given. If the work scope changes, a new permit must be issued.

**6.18.8** Authorize CSEP extensions, on a case-by-case basis, by annotating on CSEP or attaching amplifying instructions to CSEP detailing the extension.

**CSPM**

**6.18.9** Retain completed CSEP for at least one year.

**6.19 Pre-entry Briefing and Equipment Check**

**Confined Space Entry Supervisor**

**6.19.1** Perform the following prior to authorizing entry:

- A. Designate Authorized Entrants and Authorized Attendants for each permitted confined space entry after ensuring that they are trained in their confined space entry duties.
- B. Conduct a pre-entry job briefing in accordance with DND-NSE-PRO-00002, *Pre-Job Briefing and Post-Job Review*, (including a review of the CSEP) to communicate the hazards and safe work controls specified in the hazard review and to address any questions.
- C. Ensure that the engineering control equipment (e.g., lighting and ventilation) is properly utilized.
- D. Ensure that PPE is available and properly donned.
- E. Ensure that safety retrieval equipment and fall arresting devices for permit-required entries are operational and available for use at the confined space, as applicable.
- F. Ensure that the CSEPs are posted at the confined space site at the time of entry and that they reflect the most recent atmospheric testing results.
- G. **IF** posting is not practicable (e.g., manhole entry) **THEN** ensure that the CSEP (s) are available at the confined space site for review.

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 21 of 35</b>

**Authorized Attendant**

- 6.19.2** Complete initial confined space training prior to confined space work.
- 6.19.3** Conduct the following actions prior to allowing Authorized Entrants to access the permitted space:
  - A.** Visually confirm the validity of posted CSEPs.
  - B.** Notify the Confined Space Entry Supervisor of expired or invalid posted CSEPs or other permits so that they can be removed.
  - C.** Review atmospheric testing results and verify that the most recent results are documented on the CSEP and that the results are acceptable for entry.
  - D.** Ensure communication methods/equipment for maintaining continuous contact with Authorized Entrants and for summoning emergency/rescue personnel have been established and that the equipment is working.
  - E.** Maintain a record of authorized entrants performing CSEP space entries, using the Personnel Log section of CSEP.

**6.20 Performing Permitted Confined Space Entries**

**Authorized Attendant**

**NOTE**

Never enter the confined space or perform activities that may interfere with the primary duties of monitoring the entry, tracking the activities of Authorized Entrants, and summoning rescue services in an emergency. However, Authorized Attendants are not precluded from performing tasks, such as passing tools to an Authorized Entrant.

- 6.20.1** Know the hazards that may be faced during entry and exit, including information on the mode, signs or symptoms, and consequences of exposure.
- 6.20.2** Be aware of possible behavioral effects of hazard exposure.
- 6.20.3** Understand conditions requiring exit, including the following:
  - Detecting prohibited conditions or behavioral effects of hazard exposure
  - A situation outside the space that could endanger Authorized Entrants
  - If the Authorized Attendant cannot effectively and safely perform all required duties

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 22 of 35</b>

- 6.20.4** Ensure work being performed is in accordance with established requirements and that a continuous and accurate count of Authorized Entrants is maintained using a means to identify the Authorized Entrant that accurately identifies who is in the space.
- 6.20.5** Remain outside of the permit space during entry operations until relieved by another attendant.
- 6.20.6** Maintain a written log of confined space entrants for permitted entries.
- 6.20.7** Maintain effective and continuous contact with Authorized Entrants for the duration of the entry to monitor the Authorized Entrant's status and to alert entrants of the need to evacuate the space.
- 6.20.8** Continuously observe entry in only one confined space at a time.
- 6.20.9** Ensure the continued integrity of installed barriers, as necessary, to protect Authorized Entrants from hazards, external to the space (vehicles, water runoff, unauthorized personnel, etc.).
- 6.20.10** Notify the Confined Space Entry Supervisor of any unusual conditions that may adversely impact safety and health.
- 6.20.11** Monitor activities inside and outside of the space to determine if it is safe for entrants to remain in the space, and order Authorized Entrants to evacuate a confined space immediately when any of the following occurs:
  - An alarm from an air-testing or any other safety-related device is activated
  - The Authorized Attendant observes or is informed of a condition that is prohibited by the entry permit
  - Behavioral abnormalities of Authorized Entrants that may be the result of hazard exposure are detected
  - The Authorized Attendant must leave the confined space entry to prevent disruption of communications
  - Additional hazards are recognized or suspected

**NOTE**

Rescue personnel may be summoned by plant radio, telephone, fire alarm pull box, messenger, etc.

- 6.20.12** Notify emergency rescue personnel as soon as it is determined that Authorized Entrants may need assistance to escape from permit space hazards.
- 6.20.13** Perform non-entry rescues, utilizing a mechanical retrieval device, tag-line, etc., without causing injury to entrant, if possible.

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 23 of 35</b>

**6.20.14** Warn unauthorized persons that they must stay away from the permit space and prohibit them from attempting a rescue.

**6.20.15** **IF** unauthorized persons enter the permit space, **THEN** advise them that they must exit immediately and inform the Authorized Entrant and the Confined Space Entry Supervisor. The Attendant or the Confined Space Entry Supervisor determines why the unauthorized individual has entered and issues a problem report.

#### **Authorized Entrant**

**6.20.16** Review SDSs for any hazardous chemicals/materials to be used in a confined space, as needed.

**6.20.17** Maintain effective and continuous communication with the Authorized Attendant(s) while in the confined space.

**6.20.18** Perform work according to permits and procedures, always using equipment properly during confined space entries (ventilation equipment, PPE, lighting equipment, ladders, etc.).

**6.20.19** Notify the Authorized Attendant(s) if conditions change, additional confined space hazards are suspected, any warning sign or symptom of exposure to a dangerous situation is recognized, or a prohibited condition is detected.

**6.20.20** Evacuate the space immediately when any of the following occur:

- The Authorized Attendant or Confined Space Entry Supervisor orders evacuation
- A warning sign or symptom of exposure to a dangerous situation is recognized
- An evacuation alarm from an air-testing or any other safety-related device is activated
- Authorized Entrant detects a prohibited condition or believes that remaining in the space may jeopardize his/her well-being

#### **Confined Space Entry Supervisor**

**6.20.21** Post, or by equally effective means, have the completed CSEP in an easily visible location to allow Authorized Entrants or their representatives to confirm pre-entry preparations have been completed. Know the hazards that may be faced during entry, including information on the mode, signs, symptoms, and consequences of exposure to the hazards.

**6.20.22** Verify that all entry conditions on the CSEP have been addressed.

**6.20.23** Verify that rescue services are available and the means for summoning rescue services are operable.

<b>TITLE:</b>	<b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
		<b>REV. NO. 0</b>
		<b>Page 24 of 35</b>

**6.20.24** IF an off-site rescue service will be utilized, **THEN** verify rescue service availability prior to entering the PRCS.

**6.20.25** Remove unauthorized individuals who enter or attempt to enter the permit space during entry operations.

**6.20.26** Maintain copies of all exceptions applicable to specific confined space entries and ensure their accessibility for review.

**6.20.27** Coordinate multi-employer entry operations with OS&H.

**6.20.28** Ensure safety retrieval and other confined space-related equipment is inspected, as applicable.

**6.20.29** **WHEN** responsibility for a permit space entry operation is transferred, and at intervals dictated by the hazards and operations performed within the space, **THEN** determine that entry operations remain consistent with terms of the CSEP and acceptable entry conditions are maintained.

## **6.21 Post-Performance Work Activities**

### **Authorized Attendant**

**6.21.1** Confirm that all Authorized Entrants have exited the confined space safely.

**6.21.2** Report any “lessons learned” and/or problems encountered to the Confined Space Entry Supervisor.

### **Confined Space Entry Supervisor**

**6.21.3** Return completed CSEP and log to the CSPM. This must be the original and cannot be a copy that is emailed or faxed.

## **6.22 Emergency Response Actions**

### **Qualified Worker**

**6.22.1** Following discovery of an emergency, immediately summon emergency rescue support via one of the following methods:

- Dial 911 on site telephones; **OR** dial 740-897-3025 (Plant Shift Superintendent [PSS]), 740-897-5909 (Fire Department), or 740-897-2444 (emergency) on cell phones
- Plant radio
- Fire alarm pull box
- Send a messenger

TITLE:	<b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
		<b>REV. NO. 0</b>
		<b>Page 25 of 35</b>

- In person at the X-300 Plant Control Facility, the X-1007 Fire Station, or the X-104 Protective Force Headquarters Complex

**6.22.2** Remain in a nearby area to assist emergency response personnel (if it is safe to do so).

**6.22.3** IF evacuation of the affected area is required, THEN notify the emergency IC at the earliest opportunity.

**6.22.4** Perform local personnel accountability (as necessary) to identify those affected or potentially affected by the emergency.

**6.22.5** Perform other emergency support activities, as needed or requested, according to approved emergency procedures.

### **6.23 Program Evaluations**

#### **CSPM**

**6.23.1** No evaluation is necessary if there have been no confined space entries performed during a 12-month period.

**6.23.2** Log and perform a document review of all returned permits annually.

**6.23.3** Documented reviews will be used as supporting evidence in surveillance.

## **7.0 RECORDS**

### **7.1 Records Generated**

A. DND-IH-PRO-00049-F01, *Confined Space Entry Permit*

B. DND-IH-PRO-00049-F03, *Confined Space Identification and Evaluation*

### **7.2 Requirements**

Records generated or received as a result of performing this procedure shall be managed according to DND-BS-PRO-00062, *Records Management Process*.

## **8.0 DEFINITIONS/ACRONYMS**

### **8.1 Definitions**

A. **Authorized Attendant** – A trained person who is assigned to monitor, support, and react, as required, to support the Authorized Entrants' activities within a confined space.

B. **Authorized Entrant** – A trained person who is authorized to enter and perform work in a confined space.

<b>TITLE:</b>	<b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
		<b>REV. NO. 0</b>
		<b>Page 26 of 35</b>

- C. **Blinding/Blanking** – The insertion of a solid barrier across the open end of a pipe leading into or out of the confined space to secure the barrier in such a way as to prevent leakage of material into the confined space.
- D. **Competent Person** – One who is capable of identifying existing and predictable confined space hazards in the surrounding or working conditions and has authorization to take prompt corrective measures to eliminate them and is designated in accordance with DND-OS-PRD-00002.
- E. **Confined Space** – An enclosed area that has ALL of the following characteristics:
  - 1) It is large enough and configured such that an individual can bodily enter and perform assigned work.
  - 2) It is not designated for continuous employee occupancy.
  - 3) It has limited or restricted entry and exit (e.g., tanks, vessels, silos, storage bins, hoppers, vaults, and pits are spaces that may have limited means of entry.)
- F. **Confined Space Entry Permit (CSEP)** – The permit (DND-IH-PRO-00049-F01) used to establish safety boundaries and controls that help provide adequate protection for employees performing specified work that creates the potential for special or unusual hazards.
- G. **Confined Space Entry Supervisor** – The trained Line Management or contracted labor resources personnel who have direct operating authority over the work specified by the applicable permit(s) or procedure(s) being performed.
- H. **Confined Space Owner** – The SOCCo Facility Manager, Project Lead, or contracted labor resources who are assigned ownership of one or more confined spaces at a site, building, or facility.
- I. **Confined Space Program Manager (CSPM)** – The SOCCo individual responsible for managing and providing oversight for the Confined Space Program.
- J. **Double Block and Bleed** – A method used to isolate a confined space from a line, duct, or pipe by physically closing two in-line valves on a piping system and opening a” vented-to-atmosphere” valve between them.
- K. **Engulfment** – The surrounding and/or capturing of a person by divided particulate matter or liquid that can be aspirated to cause death by filling or plugging the respiratory system, or that can exert enough force on the body to cause death by strangulation, constriction, or crushing.
- L. **Entry** – Ingress into a confined space and/or work within a confined space, including breaking the plane of the confined space opening with any part of the body.

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 27 of 35</b>

- M. Flammable/Explosive Materials** – Contaminants, such as gases, vapors, or dusts, that can cause an atmosphere to explode or ignite if a source of ignition is present or introduced into the environment.
  
- N. Hazardous Atmosphere** – An atmosphere that may expose employees to the risk of death, incapacitation, impairment of ability to self-rescue (i.e., escape unaided from a permit space), injury, or acute illness from one or more of the following causes:
  - 1) A flammable gas, vapor, or mist in excess of 10 percent of its lower flammable limit (LFL).
  - 2) Airborne combustible – dust at a concentration that meets or exceeds its LFL; this concentration may be approximated as a condition in which the dust obscures vision, at a distance of 5 feet (1.52 m) or less.
  - 3) An oxygen-deficient atmosphere containing less than 19.5 percent oxygen by volume or an oxygen-enriched atmosphere containing more than 23.5 percent oxygen by volume.
  - 4) An atmospheric concentration of any substance listed in 29 Code of Federal Regulations (CFR) 1910, *Occupational Safety and Health Administration*, Subpart Z, *Toxic and Hazardous Substances*, above the listed numerical value of the permissible exposure limit (PEL) or above the listed numerical value of the TLV published by the ACGIH.
  - 5) A condition immediately dangerous to life or health, as defined in this section. For air contaminants for which Occupational Safety and Health Administration (OSHA) has not determined a dose or PEL; other sources of information, such as SDS that comply with the Hazard Communication Standard, published information, and internal documents can provide guidance in establishing acceptable atmospheric conditions.
  
- O. Hot Work** – Work within a confined space that produces arcs, sparks, flames, heat, or other sources of ignition.
  
- P. Immediately Dangerous to Life or Health (IDLH)** – Defined as any condition that poses an immediate or delayed threat to life or one that may result in irreversible health effects, or other conditions that could impair unaided escape from a confined space.
  
- Q. Incident Commander (IC)** – The individual in overall charge of an emergency response at PORTS who is the PSS or his/her designee.
  
- R. Inerting** – Displacement of the atmosphere by a non-reactive gas (such as nitrogen) to such an extent that the resulting atmosphere is noncombustible.
  
- S. Isolation** – A process of physically interrupting or disconnecting pipes, lines, or energy sources from a confined space. The application of LOTO devices does not constitute isolation.

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 28 of 35</b>

- T. Lockout/Tagout (LOTO)** – The authorized placement and administrative control of tags and locks used to ensure the protection of personnel according to DND-OS-PRO-00068.
- U. Lower Explosive Limit/Upper Explosive Limit (LEL/UEL)** – The LEL is the minimum concentration of a flammable gas or vapor in air (usually expressed in percentage by volume at sea level) that will ignite if an ignition source is present. Concentrations below this limit are too lean to burn. The highest concentration that can be ignited is its UEL. Above that concentration, the mixture is too rich to burn. (Also LFL and Upper Flammable Limit.)
- V. Non-Permitted Confined Space** – A confined space that does not contain or (with respect to atmospheric hazards) have the potential to contain any hazard capable of causing death or serious physical harm.
- W. Permissible Exposure Limit (PEL)** – Airborne concentrations of substances to which it is believed that nearly all workers may be repeatedly exposed day after day without adverse health effects as determined by OSHA.
- X. Permit-Required Confined Space (PRCS)** – Confined space that has one or more of the following characteristics:
- Contains or has the potential to contain a hazardous atmosphere
  - Contains a material that has the potential of engulfing an entrant
  - Has an internal configuration such that an entrant could be trapped or asphyxiated by inwardly converging walls or by a floor that slopes downward and tapers to a smaller cross-section
  - Contains any other recognized serious safety or health hazard
- Y. Purging** – The method by which gases, vapors, or other airborne impurities are displaced from a confined space. This process may involve such measures as mechanical ventilation, steam ventilation, or introduction of another gas such as nitrogen or carbon dioxide to control flammable vapors.
- Z. Qualified Worker** – For the purposes of this procedure, a person who is trained to perform confined space work.
- AA. Retrieval System** – The equipment (including a retrieval line; full-body harness; wristlets, if appropriate; and a lifting device or anchor) used for non-entry rescue of persons from confined spaces.
- BB. Risk** – For the purposes of this procedure, a function of both the probability and severity of occurrence of potential or known hazards.
- CC. Risk Evaluation** – A process to assess the type, probability, and severity of the combination of potential and known hazards for a confined space entry.

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 29 of 35</b>

**DD. Threshold Limit Value (TLV)** – A value developed by the ACGIH for airborne concentrations of substances under conditions where it is believed that nearly all workers may be repeatedly exposed day after day without adverse effect.

**EE. Toxic Atmosphere** – An atmosphere containing a concentration of a substance above published or otherwise known safe levels capable of producing an adverse effect on human health.

## 8.2 Acronyms

- A. ACGIH** – American Conference of Governmental Industrial Hygienists
- B. ANSI** – American National Standards Institute
- C. CFR** – Code of Federal Regulations
- D. CPR** – Cardiopulmonary Resuscitation
- E. GFCI** – Ground-Fault Circuit Interrupter
- F. JHA** – Job Hazard Analysis
- G. LFL** – Lower Flammable Limit
- H. OS&H** – Occupational Safety and Health
- I. OSHA** – Occupational Safety and Health Administration
- J. PORTS** – Portsmouth Gaseous Diffusion Plant
- K. PSS** – Plant Shift Superintendent
- L. PPE** – Personal Protective Equipment
- M. SCBA** – Self-contained Breathing Apparatus
- N. SDS** – Safety Data Sheet
- O. SOCCo** – Southern Ohio Cleanup Company LLC

<b>TITLE:</b>  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 30 of 35</b>

**Appendix A**  
**SOURCE REFERENCES AND REGULATORY REQUIREMENTS**

1. 10 CFR 851, *Worker Safety and Health Program*
2. 29 CFR 1910.146, *Permit-Required Confined Spaces*
3. 29 CFR 1926.1200, Subpart AA, *Confined Spaces in Construction*
4. 29 CFR 1926.651, *Specific Excavation Requirements, Appendix G, Hazardous Atmospheres*
5. American National Standards Institute (ANSI) Z117.1-2009, *Safety Requirements for Confined Space*
6. ANSI Z535.1-1998, *Safety Color Code*, revision of ANSI Z53.1-1979
7. ANSI Z535.2-1998, *Environmental and Facility Safety Signs*, revision and combination of ANSI Z35.1-1972 and ANSI Z35.4-1972
8. DND-NSE-PRD-00001, *Conduct of Operations Program*
9. National Fire Protection Association 70E, *Standards for Electrical Safety in the Workplace*

<b>TITLE:</b>  <p style="text-align: center;"><b>Confined Space Program</b></p>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 31 of 35</b>

**Appendix B  
 CONFINED SPACE DANGER SIGNS**

1. The primary purpose of posting signs for identification of confined spaces is to prevent inadvertent (i.e., accidental) entry by personnel at SOCCo sites. Posting of warning signs for confined spaces that require a permit for entry shall include at a minimum the words **DANGER CONFINED SPACE**.



2. Any alternative measures deemed as equally effective to posting for specified confined spaces shall be approved by an SOCCo Industrial Hygienist or OS&H Professional.
3. Obvious confined spaces such as manholes, ventilation ducts, and large process piping, **WHEN** access is provided for work in these particular spaces, **THEN** removable barricades shall be used to prevent inadvertent entry.
4. Signs shall be maintained in legible and durable condition (metal, heavy plastic, etc.) and attached to or near the entry with screws or other suitable devices. The size of lettering of the sign will be large enough to be readily visible and conspicuous to comply with the latest revision of ANSI Z35.4. The word *Danger* is to be printed as white letters on a red background surrounded by a black background. The other words are to be printed as black lettering on a white background.

The sign should be made of a durable material (metal, heavy plastic, etc.) and attached to or near the entry with screws or other suitable devices. The size of lettering of the sign will be large enough to be readily visible and conspicuous to comply with the latest revision of ANSI Z35.4



<b>TITLE:</b>  <p style="text-align: center;"><b>Confined Space Program</b></p>	<b>DND-IH-PRO-00049</b> <hr/> <b>REV. NO. 0</b> <hr/> <b>Page 33 of 35</b>
---	--

**Attachment A**  
**CONFINED SPACE ENTRY PERMIT**  
**Page 2 of 3**



**CONFINED SPACE ENTRY PERMIT**  
**ATMOSPHERIC TESTING / SUPERVISOR / PERSONNEL LOG**

Page \_\_\_\_ of \_\_\_\_

Atmospheric Retest Interval (Check one)

CSEP #: \_\_\_\_\_ 30 Min , 1 Hour , 2 Hour , 4 hour , 6 hour , 8 hour , Continuous

ATMOSPHERIC TESTING LOG											
Date & Time	O <sub>2</sub> (19.5-23.5%)	LEL (<10%)	Hydrogen Sulfide (<1ppm)	Carbon Monoxide (<25ppm)	Sulfur Dioxide (<0.3ppm)	Chlorine (<.5ppm)	Hydrogen Fluoride (<.5ppm)	( )	Instrument Type and S/N	Calibration Due Date	Name/Badge of Tester

SUPERVISOR LOG									
Date	Entry Supervisor (Printed)	Entry Supervisor (Signature)	Notify Rescue Service Availability (Initials)	Time (Begin/End)	Date	Entry Supervisor (Printed)	Entry Supervisor (Signature)	Notify Rescue Services Availability (Initials)	Time (Begin/End)

PERSONNEL LOG							
Date	Authorized Entrant	Badge	Time In	Time Out	Date	Attendant	Badge

Remarks: \_\_\_\_\_

TITLE:  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 34 of 35</b>

**Attachment A  
 CONFINED SPACE ENTRY PERMIT  
 Page 3 of 3**

Page \_\_\_\_\_ of \_\_\_\_\_



**CONFINED SPACE ENTRY PERMIT INSTRUCTIONS**

**CSEP is initiated by the Supervisor who has successfully completed “Confined Space Supervisor” training.**

**Guidelines are listed section by section and all information must be recorded in ink.**

1. **Permit#:** Supervisor contacts OS&H to obtain a confined space entry permit number.
2. **Confined Space Supervisor:** Individual that the CSEP will be issued to who has successfully completed “Confined Space Supervisor” training.
3. **Permit Start Date/Time:** Date/ Time permit was issued.
4. **Permit Expiration Date/Time:** Date/ Time permit expires.
5. **Location:** Specific location of where the PRCS entry will take place, e.g. vault #, equipment #, cell housing, etc.
6. **Reason For Entry:** Work scope/ activity being performed.
7. **Special Instructions:** List any special instructions or notes that are recommended by groups listed in item 8 below.
8. **CS Participants Trained:** This section is completed by the supervisor. **Untrained personnel may not enter a PRCS or serve as an attendant.**
9. **Isolation, Type of Work, Hazard Type, Atmosphere Control, Site Control, Rescue Contact, PPE, Entrant Communication, Safety/ Rescue Equipment:** Requirements are completed by the supervisor after consulting with Radiation Protection, OS&H Support Personnel, and Fire Services, as required.
10. **Permit Issued By:** Supervisor in charge of the operation where the confined space entry will occur; prints, signs, and dates the CSEP when it is issued. Signature required before posting permit at CS entry point.
11. **Permit Released By:** Supervisor in charge of the operation signs this when the permit is closed and work is completed or when permit is no longer valid due to changed conditions.
12. **Reviewed By:** Confined Space Program Manager signs after receiving and reviewing completed permit.
13. **Atmosphere Testing Log:** (Date, Time, Monitoring Equipment, etc.) is completed by personnel authorized to perform atmospheric monitoring.
14. **Supervisor Log:** The supervisor completes section of the Supervisor Log each day for the period of time that they are responsible for overseeing the work of employees in a confined space.
15. **Personnel Log:** This section must include the name(s) of all entrants and attendants, and all entry/exit dates and times. Additional space may be obtained by utilizing extra pages of this log.

Note: Confined Space Supervisor is responsible for verifying the availability of rescue services when entry is being made. Validation is required to proceed with entry.

TITLE:  <b>Confined Space Program</b>	<b>DND-IH-PRO-00049</b>
	<b>REV. NO. 0</b>
	<b>Page 35 of 35</b>

**Attachment B  
 CONFINED SPACE IDENTIFICATION AND EVALUATION**



**CONFINED SPACE IDENTIFICATION AND EVALUATION**

SPACE LOCATION: \_\_\_\_\_ ID#: \_\_\_\_\_

SPACE DESCRIPTION: \_\_\_\_\_

WORK ACTIVITY: \_\_\_\_\_

Complete this form for any space which may be considered a confined space.  
 A confined space is defined as having those **all** characteristics listed in #1 through #3 below.

- YES     NO    1. Is the space large enough and shaped so an employee can enter and work?
- YES     NO    2. Does the space have a limited or restricted means for entry or exit?
- YES     NO    3. Is the space NOT designed for continuous employee occupancy?

If the answers to **all** questions #1 through #3 above are "YES", then the space is a **Confined Space**. Continue with questions A through E below to determine if it is a **Permit Required Confined Space**.

- YES     NO    A. Does the space contain, or have the potential to contain, a hazardous atmosphere, i.e., oxygen deficiency, flammable vapors, toxic gases or dusts, etc., or pipes, ducts, vents or other entry points for potentially hazardous substances, or will volatile chemicals be used, or will painting or other work that could create a breathing hazard be performed?  
 Specify potential or known hazards: \_\_\_\_\_
- YES     NO    B. Does the space contain a material with the potential for engulfment of a worker, e.g., grain, sand or water?  
 Specify potential or known hazards: \_\_\_\_\_
- YES     NO    C. Does the space have an internal shape such that a worker could be trapped or suffocated by inwardly converging walls, floor or ceiling?  
 Specify potential or known hazards: \_\_\_\_\_
- YES     NO    D. Does the space contain other recognized serious safety or health hazards, such as: (check all that apply)
  - \_\_\_ mechanical hazards.
  - \_\_\_ exposed or vulnerable electrical wires or energized equipment.
  - \_\_\_ operational gas or chemical lines
  - \_\_\_ special hazards related to elevation or falling
  - \_\_\_ other
 Specify potential or known hazards: \_\_\_\_\_
- YES     NO    E. Will welding, cutting, torch work, or other hot work be performed?

- If you answered "NO" to **all** questions A through E, then the space is a **Non-Permit Required Confined Space**.
- If you answered "YES" to any question A through E, then the space is a **Permit Required Confined Space**.

NOTE: If work activity changes then space must be re-evaluated by a Competent Person.  
 Any person entering a Non-Permit Required Confined Space OR a Permit Required Confined Space must have the proper confined space training.

Comments:

Sign/Badge/Date \_\_\_\_\_  
 \_\_\_\_\_  
 Competent Person