



X-330 103M	X-330 106M	X-330 112M	X-330 115M	X-330 118M	X-330 121M	X-330 124M	X-330 127M	X-330 130M	X-330 133M
X-330 102M	X-330 105M	X-330 111M	X-330 114M	X-330 117M	X-330 120M	X-330 123M	X-330 126M	X-330 129M	X-330 132M
X-330 101M	X-330 104M	X-330 107M	X-330 110M	X-330 113M	X-330 116M	X-330 119M	X-330 122M	X-330 125M	X-330 128M

KEY PLAN
NO SCALE

DEMOLITION NOTE:

1. ALL VENTILATION DUCT WITHIN GRID A-H AND 17-38 TO BE REMOVED AND CAPPED. CAPPING WILL UTILIZE 18 GA. GALVANIZED PLATE, SELF-TAPPING SCREWS, HIGH-TEMPERATURE SILICONE SEALANT.
2. FILTER ROOM 2, 3, AND 4 TO BE REMOVED AND FILLED IN.
3. VENTILATION TO BE REMOVED UNDER TSCA SPECIFICATION 40 CFR 761 (9)(3)(C)

NOTE
FOR GENERAL NOTES AND REFERENCE
DRWGS SEE X-330-101M
FOR DUCT LOCATION AND DIMENSIONS
NOT SHOWN SEE DRWG X-330-103M

* DESIGN MANAGER:
APPROVAL AND DATE:

BASE DOCUMENT: X-330-109M, REV. 1 CAD OVERLAY

SCALE 1" = 1'-0"

"POOR QUALITY ORIGINAL"

This document has been reviewed and is
UNCLASSIFIED and NOT UCNL. This review
does not constitute clearance for public
release.

#192 DIG. SIGN.
Authorized Derivative Classifier Date

UNITED STATES ATOMIC ENERGY COMMISSION			
GIFFELS & VALLET, INC ENGINEERS DETROIT 26 MICHIGAN			
DRAWING TITLE HEATING AND VENTILATING GROUND FLOOR X-29 UNIT NUMBER 4			
DRAWING APPROVED - DATE C. J. GILBERT 4-15-53	DRAWING APPROVED - DATE R. A. WALKER 4-15-53	DRAWING APPROVED - DATE L. H. JACKSON 4-15-53	JOB 51-163X
DATE 9/1/52	DATE 9/1/52	DATE 9/1/52	
DRAWN C. DALBEY	ENGINEER R. A. WALKER	CHECKED R. A. WALKER	DATE 4-15-53
PROJECT X-330		BUILDING PORTSMOUTH AREA	DATE 4-15-53
SHEET NO.		TITLE	DATE
REFERENCE DRAWINGS		X-330-109M	