


X-330 103M	X-330 106M	X-330 109M		X-330 115M	X-330 118M	X-330 121M	X-330 124M	X-330 127M	X-330 130M	X-330 133M
X-330 102M	X-330 105M	X-330 108M	X-330 111M	X-330 114M	X-330 117M	X-330 120M	X-330 123M	X-330 126M	X-330 129M	X-330 132M
X-330 101M	X-330 104M	X-330 107M	X-330 110M	X-330 113M	X-330 116M	X-330 119M	X-330 122M	X-330 125M	X-330 128M	X-330 131M

1
9
17
25
33
41
49
57
65
73
81
90

KEY PLAN  
NO SCALE

**DEMOLITION NOTE:**

1. ALL VENTILATION DUCT WITHIN GRID A-H AND 17-38 TO BE REMOVED AND CAPPED. CAPPING WILL UTILIZE 18 GA. GALVANIZED PLATE, SELF-TAPPING SCREWS, HIGH-TEMPERATURE SILICONE SEALANT.
2. FILTER ROOM 2, 3, AND 4 TO BE REMOVED AND FILLED IN.
3. VENTILATION TO BE REMOVED UNDER TSCA SPECIFICATION 40 CFR 761 (9)(3)(C)

\* DESIGN MANAGER:  
APPROVAL AND DATE:

SCALE  $\frac{1}{8} = 1'-0"$

NOTE  
FOR GENERAL NOTES AND REFERENCE DRWGS.  
SEE DRWG. X-330-101M  
FOR DUCT LOCATION & DIMENSION FOR SUPPLY  
DUCTS SEE DRWGS. X-330-118M. FOR EXH DUCTS  
SEE DRWG. X-330-103M.

"POOR QUALITY ORIGINAL"

This document has been reviewed and is UNCLASSIFIED and NOT UCNI. This review does not constitute clearance for public release.

#192	DIG. SIGN.
Authorized Derivative Classifier	Date

BASE DOCUMENT: X-330-112M, REV. 1      CAD OVERLAY

A01	5/30/24	CFC PER ESO E6633-001	WKB/DKG	DIG. SIGN.
<div style="text-align: center;"> </div>				
REV NO.	DATE	ISSUED FOR		BY APP DATE
<div style="text-align: center;"> <b>UNITED STATES</b>  <b>ATOMIC ENERGY COMMISSION</b>    <b>GIFFELS &amp; VALLET, INC.</b>  <b>ENGINEERS</b>  <b>DETROIT 26 MICHIGAN</b> </div>				
DRAWING TITLE				
<b>HEATING AND VENTILATING</b> <b>GROUND FLOOR X-29 UNIT NUMBER 3</b>				
DRAWING APPROVED - DATE		DRAWING APPROVED - DATE		DRAWING APPROVED - DATE
<i>C. Daley</i> <i>5/30/24</i> <b>C. DALEY</b> ENGINEER		<b>R A WALKER</b> <i>4 16 53</i> CARBON CARBON CHIMNEY CO.		<b>L H JACKSON</b> <i>4 16 53</i> ENGINEER
DRAWN <b>C DALEY</b>	DATE <i>9/25/52</i> <b>4 6 53</b>	CHECKED <i>W. M. L...</i> <b>DATE</b> <i>4 6 53</i>	UNIT <b>3</b> <b>2553</b>	JOB <b>51-163X</b>
INCHES <i>1/4"</i> <b>1/4"</b>	DATE <b>4 6 53</b>	CHECKED <i>W. M. L...</i> <b>DATE</b> <b>4 6 53</b>	UNIT <b>3</b> <b>2553</b>	JOB <b>51-163X</b>
PROJECT X		BUILDING		SHEET
PORTSMOUTH AREA		X-330-112M		A01