


X-330 103 M	X-330 106 M	X-330 109 M	X-330 112 M		X-330 118 M	X-330 121 M	X-330 124 M	X-330 127 M	X-330 130 M	X-330 133 M
X-330 102 M	X-330 105 M	X-330 108 M	X-330 111 M	X-330 114 M	X-330 117 M	X-330 120 M	X-330 123 M	X-330 126 M	X-330 124 M	X-330 132 M
X-330 101 M	X-330 104 M	X-330 107 M	X-330 110 M	X-330 113 M	X-330 116 M	X-330 119 M	X-330 122 M	X-330 125 M	X-330 128 M	X-330 131 M

1
9
17
25
33
41
49
57
65
73
81
90

KEY PLAN
NO SCALE

DEMOLITION NOTE:

1. ALL VENTILATION DUCT WITHIN GRID A-H AND 17-38 TO BE REMOVED AND CAPPED. CAPPING WILL UTILIZE 18 GA. GALVANIZED PLATE, SELF-TAPPING SCREWS, HIGH-TEMPERATURE SILICONE SEALANT.
2. FILTER ROOM 2, 3, AND 4 TO BE REMOVED AND FILLED IN.
3. VENTILATION TO BE REMOVED UNDER TSCA SPECIFICATION 40 CFR 761 (9)(3)(C)

* DESIGN MANAGER:
APPROVAL AND DATE:

BASE DOCUMENT: X-330-115M, REV. 1 CAD OVERLAY

NOTE
FOR GENERAL NOTES AND REFERENCE DRWS
SEE DRWG X-330-101M
FOR DUCT LOCATION AND DIMENSIONS FOR
SUPPLY DUCTS SEE DRWG X-330-11AM FOR
EXH DUCTS SEE DRWG X-330-103M

"POOR QUALITY ORIGINAL"

This document has been reviewed and is UNCLASSIFIED and NOT UCNI. This review does not constitute clearance for public release.

192 DIG. SIGN
Authorized Derivative Classifier Date

DRAWING APPROVED: DATE		DRAWING CHECKED: DATE		DRAWING DESIGNED: DATE	
C. J. Strigley 4/15/53		R. A. WALKER 4-15-53 ENGINEER		L. H. JACKSON 4-16-53 ENGINEER	
DRAWN		DATE CHANGED		DATE	
C. Dalbey		2/2/58		2/2/58	
IN CHARGE		DATE		DATE	
W. J. Manner		4-6-59		4-6-59	
PROJECT		BUILDING		SHEET	
SHEET NO.		TITTLE		REV	
REFERENCE DRAWINGS		PORTSMOUTH AREA		A01	
		X-330-115M			