


- DEMO NOTES**
- CUT, CAP, AND REMOVE ALL RISERS, PIPES, SPRINKLER HEADS AND PIPE HANGERS LOCATED UNDER DUCT WORK. DUCT WORK IN THIS AREA IS TO BE REMOVED PER DUCT WORK DEMOLITION PLANS.
  - PLUG OR CAP RISERS
  - ADD LOW POINT DRAIN AS NEEDED.
  - REFER TO TFR-SE-2016-0298 AND TFR-SE-2016-0275 FOR ANY ADDITIONAL MATERIAL TO BE ORDERED.
  - FME CAP ANY CUTS IN ABANDON SYSTEMS.
  - SPRINKLER SYSTEMS SHALL NOT BE REMOVED UNTIL APPROVED BY THE DEPARTMENT OF ENERGY.



NOTE: SPRINKLER HEADS LOCATED ABOVE THE EXHAUST DUCTS HAVE BEEN REMOVED AND PLUGGED.

This document has been reviewed and is UNCLASSIFIED and NOT UCN. This review does not constitute clearance for public release.

#192 \*DIG. SIG.  
Authorized Derivative Classifier Date

HYDRANT SYMBOLS	DEVICE SYMBOLS	FITTING SYMBOLS	VALVE SYMBOLS
TWO-WAY THREE-WAY	NON-FREEZE VALVE ASSY ALARM VALVE IN RISER INSPECTOR'S TEST CONNT'N DRY-PIPE VALVE (DIFFERENTIAL TYPE) DRY-PIPE VALVE (W/QUICK OPEN DEVICE) WATER MOTOR GONG	RISER THRU FLOOR VERTICAL BEND (NOT RISER) SWING JOINT PIPE HANGER LOCATION CAP NIPPLE OR PIPE UP OR DN	GATE GLOBE ANGLE SCREW CHECK FLANGED CHECK W/G GATE (W/INDIC POST) W/G GATE (W/VALVE BOX)
PIPE SYMBOLS NEW STEEL PIPE NEW UNDERGROUND EXIST'G UNDERGROUND			

SPRINKLER SYMBOLS	
212°	INDICATE TYPE & HEAD TEMP
325° 360°	
SPECIAL SP #1	INDICATE MOTOR EXHAUST DUCT
PENDANT	NOT INSIDE DUCT
UPRIGHT HEAD INSIDE DUCT	

AUTO SPRINKLERS (COUNT)	
212°	232
325°-360°	
SPECIAL	
TOTAL HEADS THIS SHEET	232

SHEET NO.	TITLE	SHEET NO.	TITLE
	REFERENCE DRAWINGS		REFERENCE DRAWINGS

BASE DOCUMENT: X-330SP 5-4669 REVISION 3		CAD OVERLAY	
DRAWING TITLE <b>SPRINKLER PLAN</b> SYSTEM 35 AT GROUND FLOOR			
384			
DRAWING APPROVED-DATE J.D. WILKINSON 5/21/18 ARCHITECT ENGINEER			
OPERATING CONTRACTOR K. Z. 5/13/18 DATE CHECKED H.J.R. 5/13/18 DATE SCALE 5/13/18 1/8"=1'-0"			
DESIGN E.R.C. 5/13/18 DATE APPROVED 5/13/18 PROJECT BUILDING PORTSMOUTH			
SHEET X-330SP 5-4669 REV A01			